



## STANDARD OPERATING PROCEDURES(SOP)

### Temperature Control (Server Room)

1. **General** Server room should be fully equipped to keep ambient temperature at a comfortable level to allow the servers and their components to run as efficiently as possible without having to run at near dangerous levels.
2. **Scope**  
Server Room
3. **Procedure**  
Air flow for server room should be well managed so that the flow of air is consistent throughout the room.
  - a. Air conditioner must be installed
  - b. Proper temperature should be maintained
  - c. Server racks and equipment should be well ventilated
4. **Recommendation**  
A good temperature to aim for is between 20°C and 24°C. While, 27°C temperate will likely also be acceptable.
5. **Potential Risk**  
Dangerous operating temperatures will be anything over 30°C

  
**Brigadier**  
Vice Principal/Dy Chief Executive  
CMH Lahore Medical College  
& Institute of Dentistry  
(Haroon Rashid (R))

  
Maj Gen  
Principal/Chief Executive  
CMH Lahore Medical College  
& Institute of Dentistry  
(Prof Dr. Abdul Khaliq Naveed (R))